



PIPELINE GATE VALVES

HOW TO ORDER - WILLIAMS FIGURE NUMBERS

SIZE	A		B		C		D		E		F	
	BODY MATERIAL PREFIX		CLASS AND VALVE TYPE		ENDS		TRIM		BODY SUFFIX		ACCESSORIES	
	S	Stainless	18	150# Slab Gate	F	RF Flanged	0	Special Trim	none	ASTM A216 Grade WCB or WCC	none	Handwheel
			19	150# Expanding Gate	W	Butt Weld	1D	ENP Trim with Devlon Seat	LCC	ASTM A352 Grade LCC	BP	Bypass
			38	300# Slab Gate	R	RTJ	1N	ENP Trim with Nylon Seat	LCB	ASTM A352 Grade LCB	GO	Gear Operator
			39	300# Expanding Gate			1RT	ENP Trim with Reinforced Teflon Seat	WC6	ASTM A217 Grade WC6	MO	Motor Operated
			68	600# Slab Gate			61D	316 Stem/ENP Wedge with Devlon Seat	WC9	ASTM A217 Grade WC9	BS	Bare Stem
			69	600# Expanding Gate			61N	316 Stem/ENP Wedge with Nylon Seat	WC11	ASTM A217 Grade WC11		
			98	900# Slab Gate			61RT	316 Stem/ENP Wedge with Reinforced Teflon Seat	C5	ASTM A217 Grade C5		
			99	900# Expanding Gate			66D	316 Stem/316 Wedge with Devlon Seat	C12	ASTM A217 Grade C12		
			158	1500# Slab Gate			66N	316 Stem/316 Wedge with Nylon Seat	C12A	ASTM A217 Grade C12A		
			159	1500# Expanding Gate			66RT	316 Stem/316 Wedge with Reinforced Teflon Seat	316	CF8M/316		

SLAB GATE VALVE EXAMPLE:

10" 600# RF Slab Gate Valve, WCC Body and ENP Trim , Bolted Bonnet with Gear Operator - 10" 68F-1RT GO

SIZE	A	B	C	D	E	F
		68	F	1RT		GO

NOTES:

- 1) SPECIFY PIPE SCHEDULE WHEN ORDERING VALVES WITH BUTTWELDED ENDS.
- 2) ALL VALVES ARE NACE MR-0175 COMPLIANT.